



Triggered Source Monitoring and Reporting Violation: Groundwater Rule

City of Pilot Point/ PWS 0610005 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the groundwater system during May 2018. This monitoring is required by The Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active groundwater well source. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

What should I do?

There is nothing you need to do at this time.

What is being done?

We have tested all 6 wells that were active at the time of the sample in order to be in compliance. We will also be testing at entry points for our own records.

For more information, please contact Trent Vandagriff or Bruce Walker at 940-686-2165 Ext: 600.